







NOTES:

- SOME ITEMS REMOVED FOR CLARITY.
- INLET PIPE MUST BE INSTALLED AT A WIDTH EQUIVALENT TO HALF OF THE PRIMARY TREATMENT CHAMBER WIDTH.
- INTERCEPTOR CLEANOUT MANWAY CAN BE SIZED AS 8", 16" OR 24".
- A 24" StormTEE MANWAY AND SEDIMENT REMOVAL
- MANWAY IS REQUIRED.
 INTERCEPTOR CLEANOUT MANWAY MUST BE CENTERED ABOVE THE INTERCEPTOR.
- BIOMICROBICS RECOMMENDS A 1-2% PIPE SLOPE INTO THE SYSTEM AND BEFORE THE INVERT.
- DEPENDING ON PROJECT REQUIREMENTS, PRIMARY AND SECONDARY CHAMBERS MAY BE CONSTRUCTED SEPARATELY.
- TOTAL FOOT ASSEMBLY HEIGHT SHOULD NOT BE LESS THAN 12 INCHES.

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BIO-MICROBICS, INC., ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BIO-MICROBICS, INC. IS	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES AND TOLERANCES ARE AS FOLLOWS X°±1° .X±.50 .XX±.25	BIO MICROBIO	
PROHIBITED. DO NOT SCALE DRAWING	ESG DATE: 4/12//2024	DESCRIPTION BIOSTORM 1.0 TANK	
SHEET 3 OF 4	APPROVED BY:	DETAILS PART NUMBER	REV
SCALE: SIZE: B	APPROVED BY DATE: 4/12//2024	biostorm 1.0	Α

